


Rurociągi wykonane z rur Aquatherm:
Typ Stabi Glass BluePipe MF SDR 11 20 x 1,9 mm



Rurociągi wykonane z rur Aquatherm:
Typ Stabi Glass BluePipe MF SDR 11 25 x 2,3 mm

L.p.	Nazwa komponentu	Oznaczenie	Ilość	Producent
1.	KLIMAKOWEKTOR	FWT-02CT / FWT-04CT	3	DAIKIN
2.	ZAWÓR ODCINAJĄCY	20 mm	3	Aquatherm
3.	ZAWÓR REGULACYJNY	STAD 15	3	TA HYDRONICS
4.	KLIMAKOWEKTOR	CWM-2-S	1	CW
5.	ZAWÓR ODCINAJĄCY	25 mm	1	Aquatherm
6.	ZAWÓR REGULACYJNY	STAD 20	1	TA HYDRONICS
7.	ODPOWIETRZNIK AUTOMATYCZNY	1/2"	1	FLEXVENT

ZM.		DATA		OPIS ZMIANY				WYKONAŁ	SPRAWDZIŁ	ZATWIERDZIŁ
KLIENT: URZĄD MORSKI w GDYNI				DATE		NAME		SIGN		
WYKONAŁ:		11.2016		M.M						
SPRAWDZIŁ:		11.2016		A.S						
WYDAŁ:		11.2016		M.M						
PROJEKT:				k/h TUCANA						
TYTUŁ:				SCHEMAT INSTALACJI PODŁĄCZENIA KLIMAKONWEKTORÓW						
MASA: (kg):	SKALA:	FORMAT	POW. (m²)	Nr rysunku:				PC-383-PT/WL-04		ZMIANA: 0
-	-	A4	-							ARKUSZ: 1/1
This document is our property and the use of it in any part, copying or passing it to a third party without our knowledge and consent is violation of the document owner's rights, protection of which will be claimed according to law in force Polish Maritime Office at Gdynia										



ul. Chrzanowskiego 10
81-338 Gdynia
www.umgdy.gov.pl